

NOISE LEVEL MONITORING REPORT (October 20 TO March 21)

Month Location	Oct-20		Nov-20		Dec-20		Jan-21		Feb-21		Mar-21	
	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night
Near Canteen	53	48	58	52	53	50	55	52	54	50	53	49
Near ADM	51	50	55	51	52	49	50	48	54	51	51	50
Near OHC	54	51	60	53	55	50	57	53	55	52	56	51
Near ETP	60	55	59	52	66	61	60	57	68	62	63	60
Near Central Utility	63	56	63	58	65	62	68	64	67	64	65	62
Near MEE	53	49	55	50	56	51	58	55	56	51	55	50
Near Boiler	64	58	64	61	62	59	68	63	64	60	60	54
Near MOR WH	52	51	53	49	55	50	56	52	59	51	53	50
Near AA Control Room	64	60	65	61	68	62	65	61	67	62	68	61
Near New Transformer Area	60	58	59	52	60	55	61	57	62	57	61	58
Near Flare 1	65	63	62	59	64	56	58	54	66	56	65	52
Near Flare 2	63	61	60	55	63	58	60	57	63	58	61	59
Near Flare 3	63	60	64	57	68	64	67	63	66	60	63	61

All Result are in dB (A)

NOTE: Noise level limit - 75 dB (A) During day time (6.00 am to 10.00 pm) and 70 dB (A) During night hours (10.00 pm to 6.00 am).